Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KA846

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: T P RESORT			Phone #: (715)354-3538
Mailing Address: RT 1 BOX 161			
City: BIRCHWOOD	State: WI	Zip Code: 54817	
County: Sawyer	Co. Permit #:	Notification #:	Completed: 07-03-1996

Well Constructor (Business Name): KRAMER WELL DRILLING INC	Lic. #: 45	Facility ID # (Public Wells): 858065010
Address: N3055 COUNTY W WEYERHAEUSER WI 54895-9734		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #	Specific Capacity: 7.5

3. Well serves 3 # of CABINS
Non-community
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of EDGEWATER
Fire # (if avail.)
Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

SW SE or Govt Lot #	Section: 4	Township: 37 N	Range: 9 W

2. Well Type Replacement
of previous unique well # constructed in 30
Reason for replaced or reconstructed well ?
OLD WELL WITH BROKEN CASI

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	90

Upper Enlarged Drillhole
Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	1
	V	C		NONCAVING BR CLAY	1	15
	V	C		NON CAVING GRAY CLAY	15	83
	Q	Y		CAVING BR SAND @ GRAVE	83	90

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE SAWHILL STEEL 19 LB PER FT ASTM A53	Surface	86
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL WIRE WOUND 18 LB	86	90

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	0	

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 32 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
17 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
PUMP INSTALLER DID

13. Constructor / Supervisory Driller	Lic #	Date Signed
GJ		07-13-1996
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		8
Septic or Holding, or POWTS Tank		64
POWTS dispersal component (soil absorption unit or mound)	>	200
Sewer - Building Sanitary		14

Comment:

Created On: 08-19-1996 Updated On: 04-19-2013 Review Status:

Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MP219

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LODE, WILLIAM	Phone #: (715)354-3538
Mailing Address: RFD	
City: BIRCHWOOD	State: WI — Zip Code: 54817
County: Sawyer	Co. Permit #:
Notification #	Completed: 06-26-1998
Well Constructor (Business Name): KRAMER WELL DRILLING INC	Lic. #: 45
Facility ID # (Public Wells): 858066550	
Well Plan Approval #	
Address: N3055 COUNTY W WEYERHAEUSER WI 54895-9734	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #	Common Well #
Specific Capacity: 2.1	

1. Well Location

Town of EDGEWATER

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NW SE or Govt Lot #	Section: 4	Township: 37 N	Range: 9 W

2. Well Type New Well

of previous unique well # GU409 constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves # of

Non-community

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	126

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	I			TOPSOIL	Surface	1
Q	S			CAVING BR SAND	1	12
V	C			NONCAVING BR CLAY	12	20
V	C			NONCAVING GRAY CLAY	20	110
V	Y	C		NONCAVING GRDADY SAND GRAVEL @ CLAY	110	121
Q	Y			CAVING BR SAND @ GRAVEL	121	126

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE SAWHILL STEEL 19 LBS FT ASTM A53	Surface	125
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL WIRE WOUND #18	122	126

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	0	

9. Static Water Level

33 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

21 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
GJ		07-03-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	25	Sewer - Building Sanitary	>	10
POWTS dispersal component (soil absorption unit or mound)	>	50	Building Overhang		10

Comment:

Created On: 09-25-1998 Updated On: 10-29-2018 Review Status:

Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZX195

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BEAR PAW RESORT			Phone #
Mailing Address: 2220N OLD HAYES RD			
City: BIRCHWOOD	State: WI	Zip Code: 54817	
County: Sawyer	Co. Permit #:	Notification #: 7742669201	Completed: 08-27-2019

Well Constructor (Business Name): KRAMER WELL DRILLING LLC	Lic. #: 8118	Facility ID # (Public Wells): 858030910	
Address: PO BOX 71 WEYERHAEUSER WI 54895		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 6.7	

1. Well Location

Town of EDGEWATER

Fire # (if avail.): 2220N

Street Address or Road Name and Number: OID HAYES RD

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): 45.7137 °N -91.4897 °W			Method Code: GPS008
NW SE or Govt Lot #:	Section: 4	Township: 37 N	Range: 9 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of CAMP GROUND

Non-community

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	126

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	Q	I		K-BLACK Q-CAVING I-SOIL-ORGANIC	Surface	1
T	V	C		T-TAN/BROWN V-NON-CAVING C-CLAY	1	16
G	Q	C		G-GRAY Q-CAVING C-CLAY	16	115
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	115	126

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. IPSCO STEEL 19#/FT ASTM A53	Surface	120
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S.S. WIREWOUND #20&15	120	126

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

37 ft. below ground surface

10. Pump Test

Pumping level 46 ft. below surface

Pumping at 60 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

23 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AFH	7393	08-28-2019
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Building Sanitary		66	Septic or Holding, or POWTS Tank		43

Comment:

Created On: 08-28-2019 Updated On: 10-01-2021 Review Status: APPROVED